

**General Notes:**

- This drawing is to be read in conjunction with all relevant Architects and Structural Engineers Construction issued drawings, Fire Certificate and Fire Drawings, along with the consultants Mechanical and Electrical specifications and any other documentation.
- Do not scale from this drawings. This drawings is representative only. All dimensions are in millimeters (mm), unless otherwise stated. Use the figured dimensions when shown.
- The exact location of all services and fittings to be agreed on site with the Architect and/or Structural Engineer prior to their installation.
- The Mechanical and Electrical Services are to be coordinated with all other trades and to be agreed on site prior to their installation. The contractor shall allow for the setting out and installation around all obstructions. Additional costs incurred by the contractor due to the lack of coordination will not be accepted.
- Connections to all equipment to be made by the contractor.
- Any discrepancies between this drawing and on site conditions must be reported to Renaissance Engineering LTD. immediately. Any changes from this design drawing must be agreed with the Engineer in writing. A failure to gain the approval could lead to difficulty in approving payment for the variation(s).
- Installation / Construction / As-Built Drawings to be prepared by the Mechanical/Electrical Contractor with reference to the latest Architects and Structural Engineers construction issue drawings and fire certificate drawings.
- All Electrical works to comply with the National Rules for Electrical Installations, 5th Edition IS10101:2020.
- All Mechanical and Electrical works to comply with the current Building Regulations.
- All works to comply with the National Code of Practice for Customer Interface 5th Edition 2021.

— ESB 50mm Duct (@ 600mm BFGL) from Mini-Pillar to Dwelling  
— ESB 125mm Duct (@ 600mm BFGL) Circuit Layout and Final Number of Ducts to be Confirmed by the ESB  
⊠ ESB Mini Pillar (EMP) (1000x1300x900)  
— Street Lighting 100mm (@600mm BFGL) Circuit Layout and Final Number of Ducts to be Confirmed by the ESB  
⊠ Street Lighting Mini Pillar (LMP)  
— EIR 32.50mm Duct (@400mm BFGL) From Chamber to Dwelling.  
— EIR 100mm Twin Wall Green Duct (@400mm BFGL).  
⊠ EIR Chamber (EC).

**LIGHTING LEGEND:**

⊠ BGP291 DW50 - LED-HB 5.2S 730 - 5.00 (KLM) LAMP FLUX.  
⊠ LUMI STREET GEN2 MIRC0 BGP291\_DW\_50\_20LED\_5.2S\_CLO\_L90\_T30



1	18.10.22	Issued For Information	SMcD	SM
0	01.07.22	Issued For Information	SMcD	SM
Rev	Date	Revision Description	Drn.	CHKd

**Renaissance Engineering**  
 Address: 2<sup>nd</sup> Floor, 67-70 Meath Street, Dublin 8, D08 YCK4, Ireland  
 Telephone: +353 (0)1 675 0850  
 Email: info@reng.ie  
 Web: renaissanceengineering.ie

Client: **Cavan County Council**

Architect: **Wynne Gormley Gilsonan**

Job Title: **Widows Row  
Belturbet  
Co. Cavan**

Drawing Title: **Coordinated Services**

Date:	30.06.22	Scale:	1:200 @A1	Drawing No.:	22218-REN-XX-SS-DR-ME-C000	Revision:	1
Designer:	SMcD	Checked:	SM	Approved:	SM	CAD Filename: 22218-REN-XX-SS-M2-ME-C000.dwg	

